

CE prohlášení o shodě

dle Nařízení vlády č.190/2002 Sb. ve znění nařízení vlády č. 251/2003 Sb. a nařízení vlády č. 128/2004 Sb. (1989/106/ES), kterým se stanoví technické požadavky na stavební výrobky označované CE

Výrobce

Obchodní jméno: JABLOTRON ALARMS a.s.
Sídlo: Pod Skalkou 4567/33, 466 01 Jablonec nad Nisou
IČ: 28668715

prohlašuje, že výrobek

typové označení: JA-80S(JA-180S)
specifikace: Bezdrátový detektor požáru
účel použití: detekce vzniku požáru

splňuje požadavky těchto norem a předpisů, příslušných pro daný druh zařízení:

funkční parametry: ČSN EN 54-7, ČSN EN 54-5

a že je bezpečný za podmínek obvyklého použití a v souladu s návodem k obsluze. Shoda byla posouzena v souladu s § 5, bod 1, písm. b), f), nařízení vlády č. 190/2002 Sb.

Prohlášení o shodě je vydáváno na základě těchto podkladů:

Zkušební protokol č. 18/2006A vydaný akreditovanou laboratoří č. 1140 Zlabo – Lites Liberec
Zkušební protokol č. 188/06 vydaný akreditovanou laboratoří č.010/S-081EVPÚ Nová Dubnica

CPD certifikát č. 1293-CPD-0158 vydal:

Elektrotechnický výzkumný a projektový ústav a.s.
Notifikovaný orgán č. 1293
Trenčianská 19
018 51 Nová Dubnica
Slovenská republika

CE 1293 CPD 0158

Toto prohlášení je vydáno na výhradní odpovědnost výrobce.

V Jablonci nad Nisou dne 15.4.2010

Ing. Dalibor Dědek
ředitel

Tel: 483559999
Fax: 483313183
E-mail: prodej@jablotron.cz

CE Declaration of Conformity

in accordance with the Construction Product Council Directive 1989/106/EEC (CPD)

The manufacturer

Name: JABLOTRON ALARMS Inc.
Address: Pod Skalkou 4567/33
Town: Jablonec nad Nisou
Country: Czech Republic
Post/Zip code: 466 01
Entrepreneurial permit number: CZ28668715

declares that the product

Type designation: JA-80S(JA-180S)
Specification: Wireless Fire Detector
Intended purpose: Fire detection

complies with the essential requirements of Annex I, Article 2 Fire Safety and the other relevant provisions of the CP Directive, when is used for its intended purpose. The conformity attesting was carried out pursuant to Article 20 (2) and Annex III Article 13 (3) of CP Directive 1989/106/EEC

Measures for the Fire Safety Requirements:

Harmonised standards applied: EN 54-7, EN 54-5

Conformity CPD Certificate No. 1293-CPD-0158 issued by:

Electrotechnical Research and Testing Institute
Notified Body No. 1293
Trenčianská 19
018 51 Nová Dubnica
Slovak Republic

CE 1293-CPD-0158

Jablonec nad Nisou, 15.4.2010

Ing. Dalibor Dědek
director



+ TK-Nr: +420
Phone 483559999, fax 483313183
e-mail export@jablotron.cz